

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0751-CPR.2-003.0-04

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Factory made mineral wool (MW) products for thermal insulation of building
equipment and industrial installations**
(details cf. annex)

Placed on the market under the name or trade mark of

SAINT-GOBAIN ISOVER G+H AG

Bürgermeister-Grünzweig-Str. 1
67059 Ludwigshafen
Germany

and produced in the manufacturing plant

Bergisch Gladbach

Jakobstr. 10
51465 Bergisch-Gladbach
Germany

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14303:2009+A1:2013

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 21.11.2013 and will remain valid (but no longer than 02.12.2026) as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Gräfelfing, 04.03.2026

Certification Body


Ralph Alberti



A publication of extracts to the Certificate of Constancy of Performance and its annex requires the prior written approval of FIW München. Certification body accredited by DAkkS according to DIN EN ISO/IEC 17065:2013. The accreditation is only valid for the scope of accreditation listed in the annex to the certificate D-ZE-14116-01-00. This certificate replaces the issue of 02.12.2025.



Factory: Bergisch Gladbach, Jakobstr. 10, 51465 Bergisch-Gladbach, Germany

Construction product(s): Factory made mineral wool (MW) products for thermal insulation of building equipment and industrial installations according to EN 14303:2009+A1:2013

Intended use: Thermal insulation products for building equipment and industrial installations

Reaction to fire: Products for which a clearly identifiable stage in the production process results in an improvement in the reaction to fire classification by limiting of organic material.

Detailed information on reaction to fire can be found in the classification reports

Product			Reaction to fire			
Name	Form	Facing	Nominal density	Fire class	Range	Classification report
U TECH Pipe Section MT 4.0	Pipe section	-	62-90 kg/m ³	A1L / A1	Max. mass of organic content: 3,65 %	KB-Hoch-230370
U Protect Pipe Section Alu2	Pipe section	Reinforced aluminium foil	62-90 kg/m ³	A2L-s1, d0	Do ≤ 300 mm Thickness: 20 mm to 139 mm	KB-Hoch-120060
U Protect Pipe Section Alu2	Pipe section	Reinforced aluminium foil	62-90 kg/m ³	A2-s1, d0	Do > 300 mm Thickness: 50 mm to 100 mm	KB-Hoch-210813
U Protect Vent Section Alu2	Pipe section	Reinforced black aluminium foil	62-90 kg/m ³	A2L-s1, d0	Do ≤ 300 mm Thickness: 20 mm to 100 mm	KB-Hoch-210813
U Protect Vent Section Alu2	Pipe section	Reinforced black aluminium foil	62-90 kg/m ³	A2-s1, d0	Do > 300 mm Thickness: 50 mm to 100 mm	KB-Hoch-210813



Forschungsinstitut für Wärmeschutz e. V. München

Annex to Certificate of Constancy of Performance: 0751-CPR.2-003.0-04

Date: 04.03.2026



Name	Form	Facing	Nominal density	Fire class	Range	Classification report
U Protect Vent Section Alu2 / U Protect Pipe Section Black	Pipe section	Reinforced black aluminium foil	62-90 kg/m ³	A2L-s1, d0	Do ≤ 300 mm Thickness: 20 mm to 100 mm	KB-Hoch-210813
U Protect Vent Section Alu2 / U Protect Pipe Section Black	Pipe section	Reinforced black aluminium foil	62-90 kg/m ³	A2-s1, d0	Do > 300 mm Thickness: 50 mm to 100 mm	KB-Hoch-210813

Gräfeffing: 04.03.2026

Certification body

Ralph Alberti

