

# CERTIFICATE

**Number of certificate:** 035-FIW-2-015.0-02

**Holder of certificate:** **Saint-Gobain Isover G+H AG**  
Bürgerneister-Grünzweig-Str. 1  
67059 Ludwigshafen am Rhein, Germany

**Manufacturing plant:** SAINT-GOBAIN ISOVER G+H AG  
67346 Speyer, Germany

**Product:** **CLIMCOVER Lamella Mat / ML 3**

**Product description:** Lamella mat made of mineral wool according to  
EN 14303:2009+A1:2013  
(Technical properties see annex)

**Technical specification  
of certificate holder:** Data sheet CLIMCOVER Lamella Mat / ML 3 (16.03.23)

**Designation code:** MW-EN14303-T4-ST(+)-300-MV2

**AGI-destination code:** 10.02.01.99.03

**Certification Basis:** European INSULATION VDI and INSULATION KEYMARK  
Scheme for Thermal Insulation Products Revision: 2.1



035-FIW-2-015.0-02

This certificate entitles to use the above conformity mark in connection with the number of certificate. This certificate was first issued on 01.06.2021 and will remain valid as long as the factory production control requirements, the product, and the manufacturing conditions in the plant do not change significantly (but not longer than 01.06.2024).

Gräfelfing, 01.06.2023



**ANNEX to CERTIFICATE**

035-FIW-2-015.0-02

<b>Product:</b>	<b>CLIMCOVER Lamella Mat / ML 3</b>
<b>Product description:</b>	Lamella mat made of mineral wool according to EN 14303:2009+A1:2013
<b>Thickness range</b>	020-100 [mm]

<b>Certified properties:</b>																			
<b>Thermal conductivity:</b>	<table border="1"><thead><tr><th>Temperature °C</th><th>0</th><th>50</th><th>100</th><th>150</th><th>200</th><th>300</th><th>-</th><th>-</th></tr></thead><tbody><tr><td>W/(m·K)</td><td>0,036</td><td>0,044</td><td>0,056</td><td>0,072</td><td>0,091</td><td>0,145</td><td>-</td><td>-</td></tr></tbody></table>	Temperature °C	0	50	100	150	200	300	-	-	W/(m·K)	0,036	0,044	0,056	0,072	0,091	0,145	-	-
Temperature °C	0	50	100	150	200	300	-	-											
W/(m·K)	0,036	0,044	0,056	0,072	0,091	0,145	-	-											
	<b>Maximum service temperature: 300 °C</b>																		
	<b>Reaction to fire: A1</b>																		

Gräfelfing, 01.06.2023



Certification Body



Ralph Alberti