

CERTIFICATE

Number of certificate:	035-FIW-2-015.0-02
Holder of certificate:	Saint-Gobain Isover G+H AG Bürgerneister-Grünzweig-Str. 1 67059 Ludwigshafen am Rhein, Germany
Manufacturing plant:	SAINT-GOBAIN ISOVER G+H AG 67346 Speyer, Germany
Product:	CLIMCOVER Lamella Mat / ML 3
Product description:	Lamella mat made of mineral wool according to EN 14303:2009+A1:2013 (Technical properties see annex)
Technical specification of certificate holder:	Data sheet CLIMCOVER Lamella Mat / ML 3 (10.03.21)
Designation code:	MW-EN14303-T4-ST(+)-300-MV2
AGI-destination code:	10.02.01.99.03
Certification Basis:	European INSULATION VDI and INSULATION KEYMARK Scheme for Thermal Insulation Products Revision: 2.1



035-FIW-2-015.0-02

This certificate entitles to use the above conformity mark in connection with the number of certificate. This certificate was first issued on 01.6.2021 and will remain valid as long as the factory production control requirements, the product, and the manufacturing conditions in the plant do not change significantly (but not longer than 01.6.2023).

Gräfelfing, 01.06.2022



Certification Body

Ralph Alberti

Ralph Alberti

ANNEX to CERTIFICATE

035-FIW-2-015.0-02

Product:	CLIMCOVER Lamella Mat / ML 3
Product description:	Lamella mat made of mineral wool according to EN 14303:2009+A1:2013
Thickness range	0020-100 [mm]

Certified properties:

Thermal conductivity:

Temperature °C	0	50	100	150	200	300	-	-
W/(m·K)	0,036	0,044	0,056	0,072	0,091	0,145	-	-

Maximum service temperature: 300 ° C

Reaction to fire: A1

Gräfelfing, 01.06.2022



Certification Body



Ralph Alberti